

SDM120CTP

Single-Phase Multifunction DIN Rail Meter



- Measures kWh, kVArh, kW, kVA, PF, Hz, dmd, V, A, etc.
- Bi-directional measurement IMP & EXP
- Two pulse outputs
- Din rail mounting 35mm
- 5A CT connection
- Better than Class 1 accuracy

User Manual V1.0

Application

The energy-meters are used to measure single-phase applications like residential, utility and Industrial. The unit measures and displays various important electrical parameters. It equipped with a white back-lighted LCD screen for prefect reading. As well as a RS485 communication port for remote reading and monitoring. Bi-directional energy measurement makes it a good choice for solar PV energy metering. The compact design and din rail installation provides an easy and economical solution for your metering demand.

PART 1 Specification

General Specifications

Voltage AC (Un)	230V
Voltage Range	176~276V AC
Base Current (Ib)	5A
Power consumption	<2W/10VA
Frequency	50/ 60Hz(±10%)
AC voltage withstand	4KV for 1 minute
Impulse voltage withstand	6KV-1.2uS waveform
Overcurrent withstand	20I _{max} for 0.5s
Pulse output 1	1000 imp/kWh (export)
Pulse output 2	1000imp/kWh (import)
Display	LCD with white backlit
Max. Reading	999999 kWh

Accuracy

Voltage	0.5% of range maximum
Current	0.5% of nominal
Frequency	0.2% of mid-frequency
Power factor	1% of Unity
Active power	1% of range maximum
Reactive power	1% of range maximum
Apparent power	1% of range maximum
Active energy	Class 1 IEC62053-21 Class B EN50470-1/3
Reactive energy	Class 2 IEC62053-23

Environment

Operating temperature	-25°C to +55°C
Storage and transportation temperature	-40°C to +70°C
Reference temperature	23°C ± 2°C

Relative humidity	0 to 95%, non-condensing
Altitude	up to 2000m
Warm up time	5s
Installation category	CAT III
Mechanical Environment	M1
Electromagnetic environment	E2
Degree of pollution	2

Output

Pulse Output

The meter provides two pulse outputs. Both pulse outputs are passive type.

Pulse output 1 is fixed to export kWh. The constant is 1000 imp/kWh.

Pulse output 2 is fixed to import kWh. The constant is 1000imp/kWh.

Mechanics

Din rail dimensions	18x118x64 (WxHxD) DIN 43880
Mounting	DIN rail 35mm
Ingress protection	IP51 (indoor)
Material	Self-extinguishing UL94V-0

PART 2 Operation

Initialization Display

When it is powered on, the meter will initialize and do self-checking.

1		Full Screen It will last for 3 seconds.
2		Software version in kind prevail It will last for 3 seconds.

After the self-checking program, the meter display will show the total active energy (kWh)

Scroll Display by Button




There is a button on the front of the meter. After initialization and self-checking program, the meter display the measured values. The default page is total kWh. If the user wants to check other information, he needs to press the scroll button on the front panel.



Click the button, the LCD display will scroll the measurements.

Keep pressing the button for 3 seconds, the meter will get into set-up mode.




1		Total active energy (kWh) Display format: 0000.00→9999.99→10000.0→99999.9→000000→999999→0000.00
2		Import active energy (kWh) Display format: 0000.00→9999.99→10000.0→99999.9→000000→999999→0000.00
3		Export active energy (kWh) Display format: 0000.00→9999.99→10000.0→99999.9→000000→999999→0000.00
4		Voltage (V)
5		Current (A)
6		Active power (W)
7		Frequency (F)
8		Power factor (PF)

9		CT1 Primary current 5A-9999A Default: 5
10		CT2: 5A
11		Software version in kind prevail


Set-up Mode

To get into set-up mode, the user need keep pressing the button for 3 seconds. It will enter into the “SET” mode.


The meter support to set the CT 1 through button. Under the “SET” menu, pressing the button again for 3 seconds, enter into the CT1 setting mode.

	Under this menu, long press the button for 3 seconds enter to the set up mode.
	The rightmost digit will flash, press the button to select the CT1 value. (Range: 5. 10. 20. 30. 40. 50. 75. 100. 125. 150. 200. 250. 300. 400. 600)
	After the setting the value, press the button for 3 seconds to confirm the setting. Meanwhile, the display will back to the “total kWh” menu.

Wiring Diagram



Dimensions



Installation

